

SS 15.1 - Systems for Communicating Evacuation

Address:			
Building Name:			
Provided by (name):			
	Make	Model	Location
1			
2			
3			
Installation Standard:		<input type="checkbox"/> NZS 4512: <input type="checkbox"/> AS 1851: <input type="checkbox"/> AS2220:1985 <input type="checkbox"/> Specifically Designed Alternate Solution <input type="checkbox"/> Other (Historical)_____	
Inspections & Maintenance Standard:		<input type="checkbox"/> NZS 4512: <input type="checkbox"/> AS 1851: <input type="checkbox"/> AS 2220: 1985 <input type="checkbox"/> Specifically Designed Alternate Solution <input type="checkbox"/> Other (Historical)_____	
Frequency:		<input type="checkbox"/> Monthly	<input type="checkbox"/> Owner <input type="checkbox"/> IQP
		<input type="checkbox"/> Annual	<input type="checkbox"/> IQP
Inspections & Maintenance:		<p>Planned preventative maintenance and responsive maintenance should be carried out in accordance with the nominated performance and inspection standard or document, and to ensure the system will operate as required in an event where the system is required to provide protection.</p>	
Reporting:		<p>The owner must keep records of all inspection, maintenance and repairs undertaken in the previous 24 months. The records must be kept on site and as a minimum, include:</p> <ul style="list-style-type: none"> • details of any inspection, test or preventative maintenance carried out, including dates, work undertaken, faults found, remedies applied, and the person who performed the work • details of any other faults found or maintenance and repair work undertaken to maintain the system in working order, including dates, work undertaken, faults found, remedies applied and the person who performed the work 	

The information above is used to help generate the compliance schedule. If you are unsure how to complete this form please consult an IQP who is registered for the system above.